

WARNINGS:

- This product must be installed in accordance with applicable electrical and installation codes by a person familiar with the construction and operation of the product and hazards involved.
- Proper grounding is required to insure personal safety.
- All work should be preformed by a qualified electrician.
- **Ensure power is OFF before starting installation or attempting any maintenance.**

GENERAL:

- Fixture assembly is shipped assembled.
- Thoroughly inspect shipment for freight damage and notify carrier as needed.
- Verify the catalog description listed on the packing slip with the fixture and component labels.
- Contact manufacture before making any fixture alterations or for additional information as needed.

1. Disconnect Power

- Disconnect power before installation or maintenance.

2. Mounting of Luminaire

- Orient the junction box with the closed end (slotted) towards the heavy side of the ballast housing.
- Slide junction box onto ballast housing and secure as shown.
- Loosen screws to mounting adapter and slide plate until fixture hangs plumb.
- Tighten both screws to secure mounting adapter.
- Thread on ¾" safety hook and hang fixture from an approved suspension system or attach to rigid conduit.

3. Electrical Connections

- Multiple voltages wires may be present-ensure correct lead is used.
- Connect power supply voltage lead to fixture voltage lead as marked.
- Connect neutral supply lead to fixture lead marked COM
- Connect fixture ground lead (green, green tracer, predominantly green) to suitable ground.
- Cap all unused leads.

6. Install Lamp Lamps must be OPEN RATED

